

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7315-0785:0167

Page 1 of 1

CATEGORY: 7315 -- POWER UNITS

LISTEE: Cooper Wheelock Inc. 7246 16th St. E., Ste. 105, Sarasota, FL 34243
Contact: Thomas Conover (941) 487-2336
Email: thomaslconover@eaton.com

DESIGN: Models POWERPATH™ PS-6, *PS-6-B, PS-6E, *PS-6E-B, PS-8, *PS-8-B, PS-8E, *PS-8E-B, *PS-8-LP, *PS-8-B-LP, *PS-8E-LP, and *PS-8E-B-LP remote notification appliance circuit extender power supplies. Model PS-EXP notification appliance circuit extender power accessory. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC for PS-6, *PS-6-B, PS-8, *PS-8-B, *PS-8-LP, *PS-8-B-LP
240 VAC for PS-6E, *PS-6E-B, PS-8 E, *PS-8 E-B, *PS-8E-LP, and *PS-8E-B-LP

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as power supply units for use with separately listed compatible fire alarm control units and notification appliances. Authority having jurisdiction should be consulted prior to installation. The unit can be programmed to generate the three-pulse temporal fire alarm evacuation signal (for total evacuation) in accordance with NFPA 72, 2002 edition.

*Rev 11-03-15 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division