



CDT (MAPNET I®)

Description	Part No.
1. CDT PC Board F1 Fuse, .4A	562-562 208-125
2. Pull Station IAM	562-610
3. Monitor ZAM	562-571
4. 4-Wire Mon. ZAM F1 & F2 Fuses, 2A	562-575 208-048
5. Signal ZAM F1 & F2 Fuses, 2A	562-594 208-048
6. Control ZAM F1 & F2 Fuses, 2A	562-595 208-048
7. Class A Mon. ZAM	562-608
8. Class A Signal ZAM F1 & F2 Fuses, 2A	562-617 208-048
9. Addr. Smoke Detector Base w/o Heat w/o LED	617-365
	617-506
10. Addr. Smoke Detector Base w/Heat w/o LED	617-366
	617-507
11. Heat Detector IAM	562-691
12. Distributed Power IAM	562-627




F1


1



2




3



F2

4


F1



F2

5


F1




F2

6

F1




7




F2

8


F1




9



10



11




12

CDT (MAPNET II®)


Description

	Part No.
13. CDT PC Board	562-688
14. Pull Station IAM	562-942
15. Monitor ZAM	562-936
16. 4-Wire Mon. ZAM F1 & F2 Fuses, 2A	562-937 208-048
17. Signal ZAM F1 & F2 Fuses, 2A	562-939 208-048
18. Control ZAM F1 & F2 Fuses, 2A	562-940 208-048
19. Class A Mon. ZAM	562-941
20. Class A Signal ZAM F1 & F2 Fuses, 2A	562-943 208-048
21. Addr. Smoke Detector Base w/o LED w/LED	617-608 617-616
22. TrueAlarm™ Sensor Base w/sounder w/relay	617-691 617-692 617-693
23. Single Station IAM	562-945
24. Distributed Power IAM	562-944
25. Addr. Duct Housing Detector Board	562-962
26. TrueAlarm™ Duct Interface Board w/relay *w/o relay	565-124 565-143
27. TrueAlarm™ Duct Base Board w/relay *w/o relay	565-131 565-144


* Not Shown




13




14




15




F2 16 F1




F2 17 F1




18




19




F2 20 F1




21




22




23




24



25



26



27

TrueAlarm™ is protected by U.S. Patent No. 5,565,468.